

| Cat. No. | Finish | Lamps   | Width   | Height | Extension | Ballast(s) Type        | Input Voltage | Line Current | Input Watts |
|----------|--------|---|---------|--------|-----------|------------------------|---------------|--------------|-------------|
| 40620N1  | White  | (1) 26W Quad Tube Compact Fluorescent (2-Pin) | 11 1/4" | 7 1/8" | 4"        | 1 - 1 Lt. NPF magnetic | 120V          | .50 (A)      | 28          |
| 40620H2  |        |   |         |        |           | 1 - 1 Lt. HPF magnetic | 277V          | .10 (A)      | 27          |

### Features

- Diffuser:** Blown white opal glass, totally enclosed. Removable by loosening thumb screw and lifting away from backplate.
- Ballast:** Rated Class "P" thermally protected. See chart above for voltage and power factor options.
- Backplate:** Die-formed 20 ga. steel, matte white finish.
- Thumb Screw:** Turned brass.

### Mounting

Fixture is provided with a mounting plate suitable for direct mounting to most outlet boxes or directly to wall surface over an outlet box.

### Electrical

Fixtures require minimum 90°C rated supply wire.

### Finish

All painted surfaces, baked enamel.

### Labels



UL (suitable for damp locations), I.B.E.W.

Fixture conforms to Americans with Disabilities Act (ADA) Federal Regulations—Protruding Objects.

| Job Information  | Type: |
|------------------|-------|
| <b>Job Name:</b> |       |
| <b>Cat. No.:</b> |       |
| <b>Lamp(s):</b>  |       |
| <b>Notes:</b>    |       |

Lightolier a Genlyte Thomas Company [www.lightolier.com](http://www.lightolier.com)  
 631 Airport Road, Fall River, MA 02720 • (508) 679-8131 • Fax (508) 674-4710  
 We reserve the right to change details of design, materials and finish.  
 © 2002 Genlyte Thomas Group LLC (Lightolier Division) • A0902

**LIGHTOLIER**<sup>®</sup>



## CORRIDOR LIGHTING

### Footcandles on Floor

|     |     |     |     |     |     |     |     |
|-----|-----|-----|-----|-----|-----|-----|-----|
| 10' | 0.6 | 0.7 | 0.7 | 0.7 | 0.8 | 0.7 | 0.7 |
| 9'  | 0.7 | 0.8 | 0.8 | 0.9 | 0.9 | 0.9 | 0.9 |
| 8'  | 0.8 | 0.9 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 |
| 7'  | 1.0 | 1.1 | 1.2 | 1.2 | 1.2 | 1.2 | 1.1 |
| 6'  | 1.2 | 1.4 | 1.5 | 1.5 | 1.5 | 1.4 | 1.3 |
| 5'  | 1.4 | 1.7 | 1.8 | 1.8 | 1.7 | 1.6 | 1.5 |
| 4'  | 1.7 | 2.0 | 2.1 | 2.1 | 2.0 | 1.8 | 1.7 |
| 3'  | 2.0 | 2.3 | 2.4 | 2.4 | 2.2 | 2.0 | 1.8 |
| 2'  | 2.3 | 2.6 | 2.7 | 2.6 | 2.4 | 2.2 | 2.0 |
| 1'  | 2.4 | 2.7 | 2.8 | 2.7 | 2.5 | 2.3 | 2.0 |
| 0'  | 2.4 | 2.7 | 2.8 | 2.8 | 2.6 | 2.3 | 2.0 |

← Luminaire

Footcandles values are initial.  
 Luminaire mounted 6'6" above floor.  
 Corridor is 8' wide by 8' high.  
 Room Reflectances: 80% Ceiling, 50% Walls, 20% Floor.  
 For multiple luminaires add together footcandles contributed by each luminaire at point(s) desired.

**LIGHTOLIER**

**Job Information** **Type:**

Lightolier a Genlyte Thomas Company [www.lightolier.com](http://www.lightolier.com)  
 631 Airport Road, Fall River, MA 02720 • (508) 679-8131 • Fax (508) 674-4710  
 We reserve the right to change details of design, materials and finish.  
 © 2002 Genlyte Thomas Group LLC (Lightolier Division) • A0902